

**ANALYTICAL REPORT**

Lab Number: **L1917152**

Client: Environmental Laboratories Services, LLC
PO Box 472
Hewitt, NJ 07421

ATTN: Joanne Cortese

Phone: (973) 728-8044

Project Name: **1ST IMPRESSIONS CHILDCARE**

Project Number: 1ST IMP CHILDCARE

Report Date: 05/01/19

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0574), IL (200077), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #P330-17-00196).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com



Project Name: 1ST IMPRESSIONS CHILDCARE**Project Number:** 1ST IMP CHILDCARE**Lab Number:** L1917152**Report Date:** 05/01/19

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L1917152-01	FIELD BLANK-DI WATER	DW	7 PROSPECT POINT RD., LAKE HOPATCONG	04/25/19 06:01	04/25/19
L1917152-02	ROOM 3 SHORT SINK	DW	7 PROSPECT POINT RD., LAKE HOPATCONG	04/25/19 06:52	04/25/19
L1917152-03	ROOM 2 DISH SINK	DW	7 PROSPECT POINT RD., LAKE HOPATCONG	04/25/19 06:54	04/25/19
L1917152-04	KITCHEN SINK	DW	7 PROSPECT POINT RD., LAKE HOPATCONG	04/25/19 06:55	04/25/19
L1917152-05	KITCHEN BATH SINK	DW	7 PROSPECT POINT RD., LAKE HOPATCONG	04/25/19 06:56	04/25/19
L1917152-06	ROOM 1 SHORT SINK	DW	7 PROSPECT POINT RD., LAKE HOPATCONG	04/25/19 06:57	04/25/19

Project Name: 1ST IMPRESSIONS CHILDCARE
Project Number: 1ST IMP CHILDCARE

Lab Number: L1917152
Report Date: 05/01/19

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name: 1ST IMPRESSIONS CHILDCARE
Project Number: 1ST IMP CHILDCARE

Lab Number: L1917152
Report Date: 05/01/19


Case Narrative (continued)

Report Submission

All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature:

 Kelly Stenstrom

Title: Technical Director/Representative

Date: 05/01/19

METALS

Project Name: 1ST IMPRESSIONS CHILDCARE

Lab Number: L1917152

Project Number: 1ST IMP CHILDCARE

Report Date: 05/01/19

SAMPLE RESULTS

Lab ID: L1917152-01

Date Collected: 04/25/19 06:01

Client ID: FIELD BLANK-DI WATER

Date Received: 04/25/19

Sample Location: 7 PROSPECT POINT RD., LAKE HOPATCONG

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Copper, Total	ND		mg/l	0.0010	0.0004	1	04/26/19 15:00	04/30/19 11:18	EPA 3005A	3,200.8	AM
Lead, Total	ND		mg/l	0.0010	0.0003	1	04/26/19 15:00	04/30/19 11:18	EPA 3005A	3,200.8	AM



Project Name: 1ST IMPRESSIONS CHILDCARE

Lab Number: L1917152

Project Number: 1ST IMP CHILDCARE

Report Date: 05/01/19

SAMPLE RESULTS

Lab ID: L1917152-02

Date Collected: 04/25/19 06:52

Client ID: ROOM 3 SHORT SINK

Date Received: 04/25/19

Sample Location: 7 PROSPECT POINT RD., LAKE HOPATCONG

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Copper, Total	0.0548		mg/l	0.0010	0.0004	1	04/26/19 15:00	04/30/19 11:23	EPA 3005A	3,200.8	AM
Lead, Total	0.0007	J	mg/l	0.0010	0.0003	1	04/26/19 15:00	04/30/19 11:23	EPA 3005A	3,200.8	AM



Project Name: 1ST IMPRESSIONS CHILDCARE

Lab Number: L1917152

Project Number: 1ST IMP CHILDCARE

Report Date: 05/01/19

SAMPLE RESULTS

Lab ID: L1917152-03

Date Collected: 04/25/19 06:54

Client ID: ROOM 2 DISH SINK

Date Received: 04/25/19

Sample Location: 7 PROSPECT POINT RD., LAKE HOPATCONG

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Copper, Total	0.0463		mg/l	0.0010	0.0004	1	04/26/19 15:00	04/30/19 11:57	EPA 3005A	3,200.8	AM
Lead, Total	0.0006	J	mg/l	0.0010	0.0003	1	04/26/19 15:00	04/30/19 11:57	EPA 3005A	3,200.8	AM



Project Name: 1ST IMPRESSIONS CHILDCARE

Lab Number: L1917152

Project Number: 1ST IMP CHILDCARE

Report Date: 05/01/19

SAMPLE RESULTS

Lab ID: L1917152-04

Date Collected: 04/25/19 06:55

Client ID: KITCHEN SINK

Date Received: 04/25/19

Sample Location: 7 PROSPECT POINT RD., LAKE HOPATCONG

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Copper, Total	0.0654		mg/l	0.0010	0.0004	1	04/26/19 15:00	04/30/19 12:02	EPA 3005A	3,200.8	AM
Lead, Total	0.0018		mg/l	0.0010	0.0003	1	04/26/19 15:00	04/30/19 12:02	EPA 3005A	3,200.8	AM



Project Name: 1ST IMPRESSIONS CHILDCARE

Lab Number: L1917152

Project Number: 1ST IMP CHILDCARE

Report Date: 05/01/19

SAMPLE RESULTS

Lab ID: L1917152-05

Date Collected: 04/25/19 06:56

Client ID: KITCHEN BATH SINK

Date Received: 04/25/19

Sample Location: 7 PROSPECT POINT RD., LAKE HOPATCONG

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Copper, Total	0.0553		mg/l	0.0010	0.0004	1	04/26/19 15:00	04/30/19 12:06	EPA 3005A	3,200.8	AM
Lead, Total	0.0017		mg/l	0.0010	0.0003	1	04/26/19 15:00	04/30/19 12:06	EPA 3005A	3,200.8	AM



Project Name: 1ST IMPRESSIONS CHILDCARE

Lab Number: L1917152

Project Number: 1ST IMP CHILDCARE

Report Date: 05/01/19

SAMPLE RESULTS

Lab ID: L1917152-06

Date Collected: 04/25/19 06:57

Client ID: ROOM 1 SHORT SINK

Date Received: 04/25/19

Sample Location: 7 PROSPECT POINT RD., LAKE HOPATCONG

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Copper, Total	0.0402		mg/l	0.0010	0.0004	1	04/26/19 15:00	04/30/19 12:10	EPA 3005A	3,200.8	AM
Lead, Total	0.0006	J	mg/l	0.0010	0.0003	1	04/26/19 15:00	04/30/19 12:10	EPA 3005A	3,200.8	AM



Project Name: 1ST IMPRESSIONS CHILDCARE

Lab Number: L1917152

Project Number: 1ST IMP CHILDCARE

Report Date: 05/01/19

Method Blank Analysis Batch Quality Control

Parameter	Result Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-06 Batch: WG1230802-1									
Copper, Total	ND	mg/l	0.0010	0.0004	1	04/26/19 15:00	04/30/19 09:53	3,200.8	AM
Lead, Total	ND	mg/l	0.0010	0.0003	1	04/26/19 15:00	04/30/19 09:53	3,200.8	AM

Prep Information

Digestion Method: EPA 3005A

Lab Control Sample Analysis Batch Quality Control

Project Name: 1ST IMPRESSIONS CHILDCARE
Project Number: 1ST IMP CHILDCARE

Lab Number: L1917152
Report Date: 05/01/19

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-06 Batch: WG1230802-2								
Copper, Total	96		-		85-115	-		
Lead, Total	101		-		85-115	-		

Project Name: 1ST IMPRESSIONS CHILDCARE

Project Number: 1ST IMP CHILDCARE

Sample Receipt and Container Information

Were project specific reporting limits specified?

NO

Cooler Information**Cooler** **Custody Seal**

A Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L1917152-01A	Plastic 250ml HNO3 preserved	A	<2	<2	3.7	Y	Absent		CU-2008T(180),PB-2008T(180)
L1917152-02A	Plastic 250ml HNO3 preserved	A	<2	<2	3.7	Y	Absent		CU-2008T(180),PB-2008T(180)
L1917152-03A	Plastic 250ml HNO3 preserved	A	<2	<2	3.7	Y	Absent		CU-2008T(180),PB-2008T(180)
L1917152-04A	Plastic 250ml HNO3 preserved	A	<2	<2	3.7	Y	Absent		CU-2008T(180),PB-2008T(180)
L1917152-05A	Plastic 250ml HNO3 preserved	A	<2	<2	3.7	Y	Absent		CU-2008T(180),PB-2008T(180)
L1917152-06A	Plastic 250ml HNO3 preserved	A	<2	<2	3.7	Y	Absent		CU-2008T(180),PB-2008T(180)

Project Name: 1ST IMPRESSIONS CHILDCARE**Lab Number:** L1917152**Project Number:** 1ST IMP CHILDCARE**Report Date:** 05/01/19

GLOSSARY

Acronyms

DL	- Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
EDL	- Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).
EMPC	- Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.
EPA	- Environmental Protection Agency.
LCS	- Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LCSD	- Laboratory Control Sample Duplicate: Refer to LCS.
LFB	- Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LOD	- Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
LOQ	- Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.) Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
MDL	- Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
MS	- Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.
MSD	- Matrix Spike Sample Duplicate: Refer to MS.
NA	- Not Applicable.
NC	- Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.
NDPA/DPA	- N-Nitrosodiphenylamine/Diphenylamine.
NI	- Not Ignitable.
NP	- Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.
RL	- Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
RPD	- Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.
SRM	- Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.
STLP	- Semi-dynamic Tank Leaching Procedure per EPA Method 1315.
TEF	- Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.
TEQ	- Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.
TIC	- Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Footnotes

Report Format: DU Report with 'J' Qualifiers



Project Name: 1ST IMPRESSIONS CHILDCARE
Project Number: 1ST IMP CHILDCARE

Lab Number: L1917152
Report Date: 05/01/19

- 1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1.8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

- A** - Spectra identified as "Aldol Condensation Product".
- B** - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).
- C** - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.
- D** - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.
- E** - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.
- G** - The concentration may be biased high due to matrix interferences (i.e. co-elution) with non-target compound(s). The result should be considered estimated.
- H** - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.
- I** - The lower value for the two columns has been reported due to obvious interference.
- J** - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively Identified Compounds (TICs).
- M** - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.
- ND** - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.
- NJ** - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.
- P** - The RPD between the results for the two columns exceeds the method-specified criteria.
- Q** - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)
- R** - Analytical results are from sample re-analysis.
- RE** - Analytical results are from sample re-extraction.
- S** - Analytical results are from modified screening analysis.

Report Format: DU Report with 'J' Qualifiers



Project Name: 1ST IMPRESSIONS CHILDCARE
Project Number: 1ST IMP CHILDCARE

Lab Number: L1917152
Report Date: 05/01/19

REFERENCES

- 3 Methods for the Determination of Metals in Environmental Samples, Supplement I. EPA/600/R-94/111. May 1994.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.



Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility

EPA 624/624.1: m/p-xylene, o-xylene

EPA 8260C: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), Methyl methacrylate, 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.

EPA 8270D: NPW: Dimethylnaphthalene, 1,4-Diphenylhydrazine; SCM: Dimethylnaphthalene, 1,4-Diphenylhydrazine.

EPA 6860: SCM: Perchlorate

SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO₂, NO₃.

Mansfield Facility

SM 2540D: TSS

EPA 8082A: NPW: PCB: 1, 5, 31, 87,101, 110, 141, 151, 153, 180, 183, 187.

EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene,

3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.

Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water

EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2:** Nitrate-N, Nitrite-N; **SM4500NO3-F:** Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE,**

EPA 180.1, SM2130B, SM4500CI-D, SM2320B, SM2540C, SM4500H-B

EPA 332: Perchlorate; **EPA 524.2:** THMs and VOCs; **EPA 504.1:** EDB, DBCP.

Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT, SM9222D.**

Non-Potable Water

SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1:** Ammonia-N, **LACHAT 10-107-06-1-B:** Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2:** Nitrate-N, **SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300:** Chloride, Sulfate, Nitrate.

EPA 624.1: Volatile Halocarbons & Aromatics,

EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs

EPA 625.1: SVOC (Acid/Base/Neutral Extractables), **EPA 600/4-81-045:** PCB-Oil.

Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603.**

Mansfield Facility:

Drinking Water

EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1 Hg.**

EPA 522.

Non-Potable Water

EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.

EPA 200.8: Al, Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.

EPA 245.1 Hg.

SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.



NJ CHAIN OF CUSTODY

PAGE OF

Project Information

Project Name:
1st Impressions childcare

Project Location: *7 Prospect Point Rd
Lake Hopatcong*

Project #: _____

Project Manager: *Joanne Cortese*

ALPHA Quote #: *4086*

Turn-Around Time
 Standard Rush (ONLY IF PRE-APPROVED)

Due Date: _____ Time: _____

Westborough, MA 8 Walkup Drive
TEL: 508-898-9220 FAX: 508-898-9193
Mansfield, MA 320 Forbes Blvd
TEL: 508-822-9300 FAX: 508-822-3288

Client Information

Client: *Environmental Laboratories Services*

Address: *PO BOX 472*

Hewitt NJ 07421

Phone: *973-728-8044*

Fax: _____

Email: *envirolabnet@optonline.net*

These samples have been Previously analyzed by Alpha

For EPH you MUST indicate Category 1 or 2. Please check one of the following:

Category 1 Category 2

Date Rec'd in Lab: *4/25/19* ALPHA Job #: *L1917152*

Report Type
 Data Summary NJ Full
 NJ Reduced Other

Billing Information
 Same as Client info PO #: _____

Regulatory Requirements
 SRS-Residential/Non Residential
 SRS-Impact to Groundwater
 NJ Ground Water Quality Standards
 Other

Site Information
Is this impacted by Petroleum Yes No
If yes indicate Petroleum Product _____
Are any samples for waste disposal Yes No
Indicate below in "Sample Specific Comments"

ANALYSIS										SAMPLE HANDLING Filtration <input type="checkbox"/> Done <input type="checkbox"/> Not Needed <input type="checkbox"/> Lab to do Preservation <input type="checkbox"/> Lab to do (Please specify below)	TOTAL # BOTTLES
1	2	3	4	5	6	7	8	9	10		
<i>pb, cu</i>											

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection		Sample Matrix	Sampler's Initials													
		Date	Time															
<i>17150-01</i>	<i>Field Blank-DI water</i>	<i>4/25/19</i>	<i>0601</i>	<i>DW</i>	<i>MD</i>	<i>X</i>												
<i>02</i>	<i>Room 3 short sink</i>		<i>0652</i>			<i>X</i>												
<i>03</i>	<i>Room 2 Dish Sink</i>		<i>0654</i>			<i>X</i>												
<i>04</i>	<i>Kitchen sink</i>		<i>0655</i>			<i>X</i>												
<i>05</i>	<i>Kitchen Bath Sink</i>		<i>0656</i>			<i>X</i>												
<i>06</i>	<i>Room 1 short sink</i>		<i>0657</i>			<i>X</i>												

Container Type _____
Preservative _____

Relinquished By: *Maryann* Date/Time: *4/25/19 1530*
Received By: *Paul Mazzella* Date/Time: *4/25/19 1531*
Paul Mazzella *4/25/19 2100*

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. All samples submitted are subject to ALPHA Payment Terms.