

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

First Impressions Newton
171 High St.
Newton, NJ 07860

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	LEAD RESULT (UG/L)	ANALYSIS DATE/TIME	ACTION LEVEL (UG/L)	COPPER RESULT (UG/L)	ANALYSIS DATE/TIME	ACTION LEVEL (UG/L)
24-1357.1	Field Blank	3-13-24	06:10	<2.00	3-18-24/10:15	15	<40.0	3-19-24/10:06	1300
24-1357.2	Infant 1	3-13-24	06:00	<2.00	3-18-24/10:21	15	201	3-19-24/10:06	1300
24-1357.3	Infant 2	3-13-24	06:00	<2.00	3-18-24/10:28	15	146	3-19-24/10:08	1300
24-1357.4	Kitchen	3-13-24	06:00	<2.00	3-18-24/10:33	15	144	3-19-24/10:08	1300
24-1357.5	Room 4	3-13-24	06:05	<2.00	3-18-24/10:39	15	131	3-19-24/10:09	1300
24-1357.6	I/T Water Fountain	3-13-24	06:05	<2.00	3-18-24/10:45	15	388	3-19-24/10:10	1300
24-1357.7	Toddler 2	3-13-24	06:06	<2.00	3-18-24/10:51	15	123	3-19-24/10:10	1300
24-1357.8	Room 6-Boys Bathroom	3-13-24	06:07	<2.00	3-18-24/10:57	15	145	3-19-24/10:11	1300
24-1357.9	Room 7	3-13-24	06:08	<2.00	3-18-24/11:03	15	134	3-19-24/10:11	1300
24-1357.10	PS Water Fountain	3-13-24	06:11	<2.00	3-18-24/11:09	15	354	3-19-24/10:12	1300
24-1357.11	Room 10	3-13-24	06:12	<2.00	3-18-24/11:32	15	156	3-19-24/10:14	1300
24-1357.12	Room 8	3-13-24	06:09	<2.00	3-18-24/11:38	15	144	3-19-24/10:14	1300
24-1357.13	Room 9	3-13-24	06:11	<2.00	3-18-24/11:44	15	218	3-19-24/10:15	1300
24-1357.14	Adult Bathroom	3-13-24	06:13	<2.00	3-18-24/11:50	15	214	3-19-24/10:16	1300
24-1357.15	Office	3-13-24	06:13	<2.00	3-18-24/11:56	15	198	3-19-24/10:16	1300
24-1357.16	Rom 6-Girls Bathroom	3-13-24	06:19	<2.00	3-18-24/12:02	15	181	3-19-24/10:17	1300
24-1357.17	Toddler Bathroom	3-13-24	06:20	<2.00	3-18-24/12:08	15	191	3-19-24/10:18	1300
24-1357.18	PS1/2 Bathroom	3-13-24	06:20	<2.00	3-18-24/12:14	15	233	3-19-24/10:19	1300
24-1357.19	Room 8 Bathroom	3-13-24	06:21	<2.00	3-18-24/12:20	15	154	3-19-24/10:19	1300

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
pH expressed in units
< = Less Than
MRL = Minimum Reporting Limit
Lead Method 200.9-MRL 2
Copper Method 3111B-MRL 40
Action Level-Lead 15 ug/l
Action Level-Copper 1300 ug/l

Examined By: *Margaret Ellis*
Lab Manager

Date: 3-20-24

CHAIN OF CUSTODY

J.R. Henderson Labs, Inc.
 123 Seaman Ave
 Beachwood, NJ 08792
 732-341-1211
 Fax: 732-505-1658

Customer Name:
Customer Address:
Phone #:
Email Address

First Impressions Newton
 171 High St., Newton, NJ 07860
 Colleen 973-383-1242
 firstimpressionsnewton@yahoo.com

Type of Sample
 Aq= Aqueous
 S= Soil
 MW= Monitoring Well
 TB= Trip Blank
 FB= Field Blank
 WW= Waste Water

OFFICE USE ONLY

Sample ID #	Type	Date	Time	Location	# of Bottles	Bact-Total Coliform	Bact-Fecal Coliform	Nitrates	Secondaries	Inorganics	Lead & Copper	Iron	Manganese	pH	THM's	HAA5	VOC	Arsenic	COD	TSS	TDS	Alkalinity	Temperature	Radiologicals	Ammonia Nit.	Sodium	Chloride	
24-1357.1	AQ	3/13/24	6:10	Field Blank	1						X																	
24-1357.2	AQ	3/13/24	6:00	INTAKE 1	1						X																	
24-1357.3	AQ	3/13/24	6:00	INTAKE 2	1						X																	
24-1357.4	AQ	3/13/24	6:00	KITCHEN	1						X																	
24-1357.5	AQ	3/13/24	6:05	ROOM 4	1						X																	
24-1357.6	AQ	3/13/24	6:05	ILT water fountain	1						X																	
24-1357.7	AQ	3/13/24	6:06	TODDLER 2	1						X																	
24-1357.8	AQ	3/13/24	6:07	Room w Boys BR	1						X																	
24-1357.9	AQ	3/13/24	6:08	Room 7	1						X																	
24-1357.10	AQ	3/13/24	6:11	PS water fountain	1						X																	
24-1357.11	AQ	3/13/24	6:12	Room 10	1						X																	
24-1357.12	AQ	3/13/24	6:09	Room 8	1						X																	
24-1357.13	AQ	3/13/24	6:11	Room 9	1						X																	
24-1357.14	AQ	3/13/24	6:13	ADULT BATHROOM	1						X																	
24-1357.15	AQ	3/13/24	6:13	OFFICE	1						X																	
24-1357.16	AQ	3/13/24	6:19	Room w Girls BR	1						X																	
24-1357.17	AQ	3/13/24	6:20	TODDLER BR	1						X																	
24-1357.18	AQ	3/13/24	6:20	PS 12 BR	1						X																	
24-1357.19	AQ	3/13/24	6:21	Room 8 BR	1						X																	

Relinquished By: Colleen Riber Received By: Matthew M
 Relinquished By: _____ Received By: _____
 Relinquished By: _____ Received By: _____

Time & Date: 15:11 3/14/24 Cooler Temp: _____
 Time & Date: _____ Preservatives: _____
 Time & Date: _____ Comments: _____